

Customer Name:

Address:

City/St/Zip:

Phone:

Tech:

| Charging System Checks | Comments |
|------------------------|----------|
|------------------------|----------|

| | |
|-------------------------------------|--|
| Battery Cables Checked | |
| Battery Terminals Cleaned & Checked | |
| Battery Posts Cleaned & Checked | |
| Electrolyte Checked & Topped Off | |
| Charger Operation Checked | |
| Battery Load Tested & Recorded | |

| Cooling System Checks | Comments |
|-----------------------|----------|
|-----------------------|----------|

| | |
|--|--|
| Fan Belt Checked | |
| Radiator Hose Checked | |
| Air Duct Checked | |
| Radiator Condition (int & ext) Checked | |
| Water Pump Checked | |
| Coolant Level Checked & Topped Off | |
| All Hose Clamps Tightened | |

| Lubrication Checks | Comments |
|--------------------|----------|
|--------------------|----------|

| | |
|-----------------------------|--|
| Oil Level - Added if needed | |
| Oil Condition Checked | |
| Replace oil as needed | |
| Oil Filter | |

| Tune Up | Comments |
|---------|----------|
|---------|----------|

| | |
|------------------------------|--|
| Air Filter change as needed | |
| Spark plugs change as needed | |
| Plug Wires Checked | |
| PCV Valve Checked | |

| Exhaust System Checks | Comments |
|-----------------------|----------|
|-----------------------|----------|

| | |
|--------------------|--|
| Piping Checked | |
| Muffler Checked | |
| Insulation Checked | |

Additional Notes:

Generator Maintenance Check List

Completed Date:

| | Make | Model | Serial | Size |
|------|------|-------|--------|------|
| GEN | | | | |
| ATS1 | | | | |
| ATS2 | | | | |
| ATS3 | | | | |

| Fuel System Checks | Comments |
|--------------------|----------|
|--------------------|----------|

| | |
|---|--|
| Fuel Lines Checked | |
| Fuel Solenoid Checked | |
| Fuel Level Checked & Recorded | |
| Fuel System Leak Checked | |
| Gas dip switch Setting on PCB -LP Or NG | |

| Gas Pressure Checks | Comments |
|---------------------|----------|
|---------------------|----------|

| | |
|-----------------------|--|
| Generator Not Running | |
| Generator Running | |

| General System Checks | Comments |
|-----------------------|----------|
|-----------------------|----------|

| | |
|--------------------------------|--|
| Electrical Connections Checked | |
| Mechanical Connections Checked | |

| Operating Condition Checks | Comments |
|----------------------------|----------|
|----------------------------|----------|

| | |
|--|--|
| AC Voltage Checked, Adjusted, Recorded | |
| AC Frequency Check, Adjust, Record | |
| AC Amps Recorded Each Phase | |
| Exercise Full Speed | |

| Transfer Switch & System Test | Comments |
|-------------------------------|----------|
|-------------------------------|----------|

| | |
|-------------------------------------|--|
| Engine Time Delay Checked | |
| Emergency Transfer Power Checked | |
| Retransfer to Utility Power Checked | |
| Cool Down Time Delay Checked | |

| Engine Safeties | Comments |
|-----------------|----------|
|-----------------|----------|

| | |
|------------------------------------|--|
| Oil Pressure Shutdown Check | |
| High Temperature Shut Down Checked | |
| Over Crank Safety Checked | |
| Over Speed Safety Checked | |

| Inspect Anchor System | Comments |
|-----------------------|----------|
|-----------------------|----------|

| | |
|---------------------|--|
| Stainless / Replace | |
|---------------------|--|

| Monitoring |
|------------|
|------------|

| | |
|--------------------|--------------------------|
| Hours Ran | <input type="checkbox"/> |
| Generator Location | ATS Location |
| Fuel Location | Weekly Test |